





FIG. 635

Junior Top Beam Clamp



- SERVICE:** For use under roof installations with bar joist type construction where the thickness of the joist does not exceed $\frac{5}{8}$ ".
- MATERIAL:** Malleable Iron casting or 304 Stainless Steel
- FINISH:** Black or Electro-Galvanized
- STANDARDS:** MSS SP-58 Type 19
- APPROVALS:** FM ($\frac{3}{8}$ " & $\frac{1}{2}$ " rod), UL
- ORDERING:** Specify figure number, rod size and finish. (Furnished with a hardened cup point set screw and lock nut.)

ROD SIZE A	B	C	D	E	F	MAX PIPE SIZE	WEIGHT EACH, LBS.	MAX. REC. LOAD, LBS.
$\frac{3}{8}$	$1\frac{5}{16}$	$1\frac{1}{2}$	$\frac{1}{2}$	1	$\frac{7}{8}$	4	0.32	350
$\frac{1}{2}$	$1\frac{5}{16}$	$1\frac{1}{2}$	$\frac{1}{2}$	1	$\frac{7}{8}$	4	0.32	470
$\frac{5}{8}$	$1\frac{3}{4}$	$1\frac{3}{4}$	$\frac{5}{8}$	$1\frac{3}{8}$	$1\frac{1}{8}$	5	0.58	550
$\frac{3}{4}$	$1\frac{7}{8}$	$1\frac{7}{8}$	$\frac{5}{8}$	$1\frac{3}{8}$	$1\frac{3}{8}$	6	0.82	700
$\frac{7}{8}$	$2\frac{3}{8}$	$1\frac{7}{8}$	$\frac{5}{8}$	$1\frac{3}{8}$	$1\frac{3}{8}$	8	0.80	1000



NOTE: FIG. #635 $\frac{3}{8}$ " Electro-Galvanized is substituted with a FIG. #638 Domestic Jr. Top Beam Clamp $\frac{3}{8}$ " Electro-Galvanized.